

**Addendum No.2, IFB 16-40**



**CITY OF SOMERVILLE, MASSACHUSETTS**  
**Department of Purchasing**  
**JOSEPH A. CURTATONE**  
**MAYOR**

To: Prospective Bidders IFB 16-40, HVAC: Preventative Maintenance, Repairs and Controls for Municipal Buildings & Schools

From: Orazio DeLuca, MCPPO  
Contract Manager

Date: November 19, 2015

Re: Questions/Answers

**Addendum No. 2 to IFB 16-40**

---

The City is issuing this addendum to IFB 16-40 HVAC Preventative Maintenance, Repairs and Controls for Municipal Buildings & Schools to answer the following questions:

**1. Could you please let me know what kind of front end is being used with the CARE system? XBS, Symmetry or EBI.**

**Answer: EBI**

**Reminder: Bids are due on Wednesday, November 25, 2015 @ 11:00**

**\*\*PLEASE BE SURE TO ACKNOWLEDGE THIS ADDENDUM ON BID PRICING PAGE\*\***

