

Addendum #1 – IFB 16-70 REBID



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB 16-70 ADA Signage Upgrade Installation

From: Michael Richards, Procurement Analyst

Date: 4/8/2016

Re: Answer questions, append bid holders list

Addendum No. 1 to IFB 16-70 REBID

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum #1 – IFB 16-70 REBID

Questions and Answers

Q. What sign types should we use when there are none listed? As an example, there is no Emergency Exit sign design within the IFB 16-70 REBID ADA Signage Upgrade Installation pdf. There is an Exit Route Stair sign and there is an Exit Ramp, but no Emergency Exit sign designs.

A. The signs shown on drawings A-01 through A-18 show sign size and layout. The text will differ from sign to sign. In the example given, on sign 3.01, “Stair 1” and “Emergency Exit” and a pictogram will appear on a sign of the same size and layout as that shown on drawing A-07, as noted in the column titled Drawing Reference.

Q. Can 1/8” non-glare acrylic painted 2nd surface (to match existing signs) using 1/32” tactile and Grade II braille be substituted instead of the photopolymer process?

A. The City will accept and consider bids providing substitute products that are equal to or better than those required in the specifications. Samples may be requested to determine if the materials are equal or better products than our specifications and can make the final determination before awarding the contract. The City has the right to make the final determination as to whether an alternate brand is equal to the brand specified.

IFB 16-70 REBID ADA Signage Upgrades
Register of Prospective Bidders / Bid Holders

[illegible]