

Addendum No. 1 to IFB 17-56



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: All Parties on Record with the City of Somerville as Holding IFB 17-56,
Powder House Boulevard and Properzi Way Water Main

From: Michael Richards, Assistant Purchasing Director

Date: March 10th, 2017

Re: Answer questions, append bid holders list as of 12:30pm 3/10/2017

Addendum No. 1 to IFB 17-56

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum No. 1 to IFB 17-56

Questions from Prospective Bidders

1) Is full-time seismic monitoring required at each work area throughout the course of the entire project?

A. Vibration monitoring is required at each site while work is being performed at that location, full time monitoring outside of those locations and working hours is not required.

2) Is the Owner's LSP responsible for waste profile preparation, LSP Opinions, and BOL/MSR preparation?

A. The contractor's environmental professional is responsible for waste profile preparation, and preparation of Bills of Lading and Material Shipping Records in accordance with the requirements of specification section 02080. The City's LSP will prepare any LSP opinions, and review and coordinate with the Contractor on waste profile and BOL/MSR preparation.

3) Is MassDot Pre-qual required for this project?

A. No.

4) Are some of the drawings missing as on page 5 it calls for there to be 15 pages of drawings and I am only seeing 5 in the package?

A. All stamped drawings are included in this set (16 pages total) on the City's bid page. The bid specifications have been checked and verified to contain all associated drawings in the appendices, Environmental summary and boring logs. One guess why this may not show up is if someone is trying to print to a standard printer, some drawing sizes are 22"x34" within the specifications, and won't let you print that size.

IFB #17-56 Powder House and Properzi Water Main
Register of Prospective Bidders / IFB Holders

[illegible]