

Addendum #2 – IFB 16-70 REBID



**CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR**

To: All Parties on Record with the City of Somerville as Holding IFB 16-70 ADA Signage Upgrade Installation

From: Michael Richards, Procurement Analyst

Date: 4/11/2016

Re: Amend answers to questions

Addendum No. 2 to IFB 16-70 REBID

Please acknowledge receipt of this Addendum by signing below and including this form in your proposal package. Failure to do so may subject the proposer to disqualification.

NAME OF COMPANY / INDIVIDUAL: _____

ADDRESS: _____

CITY/STATE/ZIP: _____

TELEPHONE/FAX/EMAIL: _____

SIGNATURE OF AUTHORIZED INDIVIDUAL: _____

ACKNOWLEDGEMENT OF ADDENDA:

Addendum #1 _____ **#2** _____ **#3** _____ **#4** _____

Addendum #2 – IFB 16-70 REBID

Questions and Answers

Q. Can 1/8" non-glare acrylic painted 2nd surface (to match existing signs) using 1/32" tactile and Grade II braille be substituted instead of the photopolymer process?

A. The City has determined that the project requires the photopolymer sign specifications as originally written in the bid specifications in an effort to match the existing signage as well as providing a more durable product to curtail abuse and tampering. Bidders are instructed to submit bids for photopolymer signage as specified in the bid package.

This answer supersedes the answer provided to this question in Addendum 1.