

Addendum No. 1 to IFB 17-31



CITY OF SOMERVILLE, MASSACHUSETTS
Department of Purchasing
JOSEPH A. CURTATONE
MAYOR

To: Prospective bidders IFB 17-31, Lead-Free Residential Water Meters

From: Orazio DeLuca, Contract Manager

Date: November 7, 2016

Re: Questions & Answers - Bid Specifications

Addendum No. 1 to IFB 17-31

The City is issuing this addendum to IFB 17-31, Lead-Free Residential Water Meters, to address questions received about bid specifications.

Question: Will the City accept bids on meters not AWWA C712 single jet type; as the City already has AWWA C700 positive displacement type meters in their system. Ultrasonic Meters are also available; would they be acceptable as an equal to the acceptable manufacturers and models listed?

Answer: YES. So long as the meter proposed by vendor works in unity with our existing KP AMR system, the City of Somerville will accept these meters as Equal to the acceptable manufacturers and models listed. The City of Somerville will have final approval of all meters submitted by vendors.

PLEASE BE SURE TO ACKNOWLEDGE ALL ADDENDA ON THE BID PRICING SHEET

*Thank you-
Orazio P. DeLuca
Construction Contract Manager
Purchasing Department
City of Somerville
617-625-6600 x 3407*