

CITY OF SOMERVILLE, MASSACHUSETTS Department of Purchasing

JOSEPH A. CURTATONE MAYOR

To: Prospective Bidders IFB 16-40, HVAC: Preventative Maintenance, Repairs and

Controls for Municipal Buildings & Schools

From: Orazio DeLuca.MCPPO

Contract Manager

Date: November 13, 2015

Re: Questions/Answers - Change in Bid Specifications

Addendum No. 1 to IFB 16-40

The City is issuing this addendum to IFB 16-40 HVAC Preventative Maintenance, Repairs and Controls for Municipal Buildings & Schools to answer the following questions:

1. All systems will be winterized by October (i.e., applying anti-freeze to all A/C systems, etc.), who will purchase Glycol?

Answer: The awarded vendor will be responsible for the purchase of the Glycol. Awarded vendor will handle the adding and removing of the Glycol. Vendor is responsible for the off-site storage of the Glycol.

2. Will ESCO Contract remain in force?

Answer: Yes. ESCO remains in full effect.

3. Confirm Access Control as listed is to be included (Exhibit 3)

Answer: Access Control is NOT to be included.

Somerville City Hall • 93 Highland Avenue • Somerville, Massachusetts 02143 (617) 625-6600, Ext. 3400 • TTY: (617) 666-0001 • Fax: (617) 625-1344



Addendum No.1, IFB 16-40

4. If Card Access is included should ESCS be considered as it is not on Exhibit?

Answer: Card Access is NOT included.

5. Confirm Video as listed is to be included (Exhibit 3)

Answer: Video is NOT included.

6. If Videos is included should ESCS be considered as it is not on Exhibit, also has non Honeywell Video

Answer: Video is NOT included.

7. Steam Traps are not listed and have not been included in past, are they to be included?

Answer: YES. All steam traps are to be included.

8. Engine #3 (Public Safety), shall central equipment (Boilers and associated) be include with PSB or E #3, these buildings were considered on location in the past?

Answer: These two locations are at the same address, they share one boiler system. This system should be included as part of the project scope.

All prospective vendors should completely remove and strike Exhibit Three (3) from the bid document

PLEASE BE SURE TO ACKNOWLEDGE THIS ADDENDUM ON BID PRICING PAGE

